

RWA 2011 Lead Compliance Sample Analysis (RCSA Section 19-13-B102 (e)(8))

Sample ID	Date	Lead (mg/L)	Sample ID	Date	Lead (mg/L)		
1	200340183	7012011	<0.001	47	200340565	7182011	0.003
2	200340184	7012011	<0.001	48	200340566	7182011	<0.001
3	200340185	7012011	<0.001	49	200340567	7182011	<0.001
4	200340186	7012011	<0.001	50	200340646	7182011	<0.001
5	200340187	7012011	<0.001	51	200340647	7182011	0.002
6	200340188	7012011	<0.001	52	200340648	7182011	<0.001
7	200340189	7012011	<0.001	53	200341294	7202011	<0.001
8	200340190	7012011	0.015	54	200341295	7202011	<0.001
9	200340191	7012011	0.002	55	200341296	7202011	<0.001
10	200340192	7012011	<0.001	56	200341297	7202011	0.001
11	200340193	7012011	<0.001	57	200341299	7202011	<0.001
12	200340194	7012011	0.001	58	200341300	7202011	<0.001
13	200340300	7012011	<0.001	59	200341301	7202011	<0.001
14	200340301	6232011	<0.001	60	200341302	7202011	0.002
15	200340302	6232011	0.001	61	200341303	7202011	<0.001
16	200340303	6232011	<0.001	62	200341304	7202011	<0.001
17	200340304	6232011	<0.001	63	200341305	7202011	<0.001
18	200340305	6232011	<0.001	64	200341306	7202011	<0.001
19	200340306	6232011	<0.001	65	200341307	7202011	<0.001
20	200340307	6232011	0.001	66	200341308	7202011	0.001
21	200340308	6232011	<0.001	67	200341318	7202011	<0.001
22	200340309	6232011	0.001	68	200341362	7202011	0.001
23	200340310	6232011	<0.001	69	200341363	7202011	<0.001
24	200340311	6232011	0.001	70	200341364	7202011	0.002
25	200340312	6232011	0.002	71	200341481	7202011	<0.001
26	200340313	6232011	<0.001	72	200341482	7202011	<0.001
27	200340314	6232011	<0.001	73	200341704	7232011	<0.001
28	200340315	6232011	<0.001	74	200341705	7232011	<0.001
29	200340316	6232011	<0.001	75	200341706	7232011	<0.001
30	200340317	6232011	<0.001	76	200341707	7232011	<0.001
31	200340318	6232011	<0.001	77	200341708	7232011	<0.001
32	200340348	6232011	<0.001	78	200341709	7232011	<0.001
33	200340425	7012011	<0.001	79	200341710	7232011	<0.001
34	200340552	7152011	<0.001	80	200341711	7232011	<0.001
35	200340553	7152011	<0.001	81	200341712	7232011	<0.001
36	200340554	7182011	<0.001	82	200341932	7272011	<0.001
37	200340555	7182011	<0.001	83	200341933	7272011	<0.001
38	200340556	7182011	<0.001	84	200341987	7272011	0.001
39	200340557	7182011	<0.001	85	200342077	8032011	0.001
40	200340558	7182011	0.001	86	200342078	8032011	0.002
41	200340559	7182011	<0.001	87	200342082	8032011	<0.001
42	200340560	7182011	<0.001	88	200342231	8032011	<0.001
43	200340561	7182011	<0.001	89	200342232	8032011	<0.001
44	200340562	7182011	0.001	90	200343452	7182011	0.002
45	200340563	7182011	<0.001	91	200343453	7182011	<0.001
46	200340564	7182011	<0.001	92	200343454	7012011	<0.001
				93	200343455	7012011	<0.001