

## **2025 Q1 Water Testing Results**

*The tables on the following pages show results of the Regional Water Authority's water quality testing for regulated compounds from June 2024 to March 2025.*

*Results, as well as the minimum reporting limit (MRL), are listed in parts per billion. The Regional Water Authority has contracted with American Water's national laboratory to conduct these tests. In accordance with the EPA's reporting parameters and American Water's standard reporting methodology, test results with a value less than the MRL are listed as "<MRL" or less than the minimum reporting limit. For results with a value at or higher than the MRL, the actual result is listed. An entry of "NA" indicates testing was not required during this period.*

[Next Page]

**MILL RIVER AQUIFER**

Water Quality Testing Results Q2 2024-Q1 2025



Analyte	Mt. Carmel Well Field					South Giant Well Field				North Giant Well Field				Benchmarks		
	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	MRL (ng/L)
<b>PFNA*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	4
<b>PFHxS*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFBS*†</b>	N/A	<MRL	<MRL	<MRL	N/A	N/A	<MRL	<MRL	<MRL	N/A	N/A	<MRL	N/A	<MRL	N/A	3
<b>HFPO-DA*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>Hazard Index</b>	N/A	0.0000	0.000	0.000	0.000	N/A	0.0000	0.000	0.000	0.000	N/A	0.0000	0.000	0.000	0.000	1 (unitless)
<b>PFOS*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	4.8	1.6	N/A	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFOA*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFHxA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>9CL-PF3ONS</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	2
<b>11CL-PF3OUdS</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>PFBA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>PFHpA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>ADONA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFDA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFUnA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	2
<b>NETFOSAA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>NMeFOSAA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	6
<b>PFDoA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFTrDA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	7
<b>PFTA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	8

\* Compound regulated by EPA

† PFBS is not averaged as it is not regulated as an individual compound; however, it is included in the Hazard Index calculation.

Key:

**MRL:** Method Reporting Limit, the lowest concentration of a chemical that a laboratory can reliably detect in a sample. For purposes of averaging, per regulation, results below the MRL (shown as "<MRL") are counted as zero.

**ng/L:** nanograms per liter (equivalent to parts per trillion)

**QUINNIPAC RIVER AQUIFER**

Water Quality Testing Results Q2 2024-Q1 2025



Analyte	South Cheshire Well Field <sup>‡</sup>					North Cheshire Well Field					Benchmarks
	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	MRL (ng/L)
<b>PFNA*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	4
<b>PFHxS*</b>	N/A	<MRL	<MRL	3.3000	1.1	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFBS**</b>	N/A	<MRL	3.4	3.1	N/A	N/A	<MRL	<MRL	<MRL	N/A	3
<b>HFPO-DA*</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>Hazard Index</b>	N/A	0.0000	0.002	0.332	0.111	N/A	0.0000	0.000	0.000	0.000	1 (unitless)
<b>PFOS*</b>	N/A	7.5	9.4	11.5	9.5	N/A	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFOA*</b>	N/A	5.5	4.7	4.8	5.0	N/A	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFHxA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>9CL-PF3ONS</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	2
<b>11CL-PF3OUdS</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>PFBA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>PFHpA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>ADONA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFDA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFUnA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	2
<b>NETFOSAA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>NMeFOSAA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	6
<b>PFDoA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFTrDA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	7
<b>PFTA</b>	N/A	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	8

\* Compound regulated by EPA

† PFBS is not averaged as it is not regulated as an individual compound; however, it is included in the Hazard Index calculation.

‡ South Cheshire Well Field not currently in daily operation.

Key:

**MRL:** Method Reporting Limit, the lowest concentration of a chemical that a laboratory can reliably detect in a sample. For purposes of averaging, per regulation, results below the MRL (shown as "<MRL") are counted as zero.

**ng/L:** nanograms per liter (equivalent to parts per trillion)

## HOUSATONIC RIVER AQUIFER

Water Quality Testing Results Q2 2024-Q1 2025



Analyte	Derby Well Field					Seymour Well Field					Benchmarks
	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	MRL (ng/L)
<b>PFNA*</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	4
<b>PFHxS*</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFBS**†</b>	N/A	<MRL	<MRL	pending	N/A	N/A	<MRL	<MRL	<MRL	N/A	3
<b>HFPO-DA*</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>Hazard Index</b>	N/A	0.0000	0.000	pending	0.000	N/A	0.0000	0.000	0.000	0.000	1 (unitless)
<b>PFOS*</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFOA*</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFHxA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>9CL-PF3ONS</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	2
<b>11CL-PF3OUdS</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>PFBA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>PFHpA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>ADONA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFDA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFUnA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	2
<b>NEtFOSAA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	5
<b>NMeFOSAA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	6
<b>PFDoA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	3
<b>PFTrDA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	7
<b>PFTA</b>	N/A	<MRL	<MRL	pending	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	8

\* Compound regulated by EPA

† PFBS is not averaged as it is not regulated as an individual compound; however, it is included in the Hazard Index calculation.

Key:

**MRL:** Method Reporting Limit, the lowest concentration of a chemical that a laboratory can reliably detect in a sample. For purposes of averaging, per regulation, results below the MRL (shown as "<MRL") are counted as zero.

**ng/L:** nanograms per liter (equivalent to parts per trillion)

## WATER TREATMENT PLANTS - EAST

Water Quality Testing Results Q2 2024-Q1 2025



Analyte	Lake Gaillard WTP					Lake Saltonstall WTP					Benchmarks
	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	
<b>PFNA*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	4
<b>PFHxS*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFBS**†</b>	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	3
<b>HFPO-DA*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>Hazard Index</b>	0.000	0.000	0.000	0.0000	0.000	0.000	0.000	0.000	0.000	0.000	1 (unitless)
<b>PFOS*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFOA*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFHxA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>9CL-PF3ONS</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	2
<b>11CL-PF3OUdS</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>PFBA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>PFHpA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>ADONA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFDA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFUnA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	2
<b>NEtFOSAA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>NMeFOSAA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	6
<b>PFDoA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFTrDA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	7
<b>PFTA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	8

\* Compound regulated by EPA

† PFBS is not averaged as it is not regulated as an individual compound; however, it is included in the Hazard Index calculation.

Key:

**MRL:** Method Reporting Limit, the lowest concentration of a chemical that a laboratory can reliably detect in a sample. For purposes of averaging, per regulation, results below the MRL (shown as "<MRL") are counted as zero.

**ng/L:** nanograms per liter (equivalent to parts per trillion)

**WATER TREATMENT PLANTS - WEST**

Water Quality Testing Results Q2 2024-Q1 2025



Analyte	West River WTP					Lake Whitney WTP					Benchmarks
	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	24-Jun	24-Sep	24-Dec	25-Mar	Running Annual Average	MRL (ng/L)
<b>PFNA*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	4
<b>PFHxS*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFBS**†</b>	<MRL	<MRL	<MRL	<MRL	N/A	<MRL	<MRL	<MRL	<MRL	N/A	3
<b>HFPO-DA*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>Hazard Index</b>	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1 (unitless)
<b>PFOS*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	4.0
<b>PFOA*</b>	<MRL	<MRL	<MRL	<MRL	<MRL	4.3	4.0	<MRL	<MRL	2.1	4.0
<b>PFHxA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>9CL-PF3ONS</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	2
<b>11CL-PF3OUds</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>PFBA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>PFHpA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>ADONA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFDA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFUnA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	2
<b>NEtFOSAA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	5
<b>NMeFOSAA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	6
<b>PFDoA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	3
<b>PFTrDA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	7
<b>PFTA</b>	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	8

\* Compound regulated by EPA

† PFBS is not averaged as it is not regulated as an individual compound; however, it is included in the Hazard Index calculation.

Key:

**MRL:** Method Reporting Limit, the lowest concentration of a chemical that a laboratory can reliably detect in a sample. For purposes of averaging, per regulation, results below the MRL (shown as "<MRL") are counted as zero.

**ng/L:** nanograms per liter (equivalent to parts per trillion)